



- Extract air to be ducted to existing high level outlet using 400mm Ø spiralduct.
- Exhaust to be fully welded and constructed from 100mm Ø, 2mm thick stainless steel.
- Exhaust shall terminate >1.5m above the roof and have a rain hood fitted.
- Supplied by BOSCH - All items inside CHP Enclosure, Secondary exhaust silencer, Float trap, CHP Isolation valves, CHP flexible connections
- Air vent valves to be fitted at high points
- Drain cocks to be fitted at low points

| | | | |
|----------------|----------------------------|--------------|--------------|
| Project | Blackwater Leisure Centre | | |
| Title | CHP Bosch CE70 - Schematic | | |
| Date | Design | Drawn | Scale |
| 17/10/16 | L.P | L.P | NTS |

www.QDSgroup.co.uk
 31-33 Pembroke Avenue
 Enfield, Middlesex, EN1 4HD
 Tel. 0208 805 9592 E-Mail: info@QDSgroup.co.uk
QDSGROUP
 QUALITY DIRECT SERVICES